



Ref. Certif. No.

FR\_720500

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

**Lithium-Ion Battery**  
Rechargeable Li-ion Battery

Name and address of the applicant

**Upower Electric Co., LTD**  
Room 401, A Building Huafeng Intelligence Valley-Yuanshan  
Hi-Tech Park, No.62 Yinhe Road, He'ao Community, Yuanshan  
Street, Longgang District, Shenzhen - CHINA

Name and address of the manufacturer

**Upower Electric Co., LTD**  
Room 401, A Building Huafeng Intelligence Valley-Yuanshan  
Hi-Tech Park, No.62 Yinhe Road, He'ao Community, Yuanshan  
Street, Longgang District, Shenzhen - CHINA

Name and address of the factory

**Upower Electric Co., LTD**  
Room 401, A Building Huafeng Intelligence Valley-Yuanshan  
Hi-Tech Park, No.62 Yinhe Road, He'ao Community, Yuanshan  
Street, Longgang District, Shenzhen - CHINA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CIZC-ESH-P24100234


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 21/11/2024

Signature:   
Certification Officer




## ANNEX

References, ratings and main characteristics:

| Model      | Nominal voltage<br>(V d.c.) | Rated capacity<br>(Ah) | Rated Power<br>(kWh) |
|------------|-----------------------------|------------------------|----------------------|
| UHB100S    | 51.2                        | 100                    | 5.12                 |
| UHB100-3S  | 153.6                       | 100                    | 15.36                |
| UHB100-4S  | 204.8                       | 100                    | 20.48                |
| UHB100-5S  | 256.0                       | 100                    | 25.60                |
| UHB100-6S  | 307.2                       | 100                    | 30.72                |
| UHB100-7S  | 358.4                       | 100                    | 35.84                |
| UHB100-8S  | 409.6                       | 100                    | 40.96                |
| UHB100-9S  | 460.8                       | 100                    | 46.08                |
| UHB100-10S | 512.0                       | 100                    | 51.20                |



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)



Date: 21/11/2024

Signature: Jérôme REYSSON  
Certification Officer